

ADDENDUM #1

1.0 Clarifications

1. Existing speakers on the library additional will be removed.
2. The unit in question, on the penthouse wall is a temperature sensor.
3. The roof composition is all metal deck. Roofs #2,3 & 4 have concrete on the metal deck. There is 2" insulation throughout.
4. According to the drawings, Roof #5, (west addition) is the only roof with sloped insulation.

2.0 Additions

1. Two existing brick walls on the penthouse shall be clad with metal siding to match existing profile and colour.